



### Answers to queries for ITB-SS-GDs-C/SERVICE-027-2009

1. Are there any specifications regarding the WC and WHB? We could not find any requirements in the ITB.  
Ans: The WC & WHB : White vitreous low level water closet(WC) with complete 9litres water capacity Cistern and White vitreous wash-hand bas in size 420x285mm(WHB)
2. For A/C and W/C, should it be packed in each unit or can it be transported separately?  
Also, must one bundle include 4 units? If we are to pack W/C into each unit, the number of units in one bundle may differ. Please advise us on this matter. ...  
Ans: Please we would advise that you pack them in the same container since there are going to different locations and if they are safe to transport otherwise you can transport them separately. Also note that the destinations are far apart.
3. What is the contract duration of this ITB? Or is this a bid for one-time procurement?  
Ans: This is one time procurement.
4. Annex V. Schedule of Requirements is missing from the ITB. Please provide us this part.  
Ans: Refer to price schedule
5. Please specify what point-foundation, concrete band means? (Refer to “Possibilities of Container mounting” of Annex VI. Technical Specifications).  
Ans: You need to provide pre-cast concrete blocks or point foundation upon which the prefabs will be installed .
6. Regarding the container height, there are several different measurements in the technical specifications. Would you clarify this for us?  
Is it OK if we adjust the height as long as it fits into the ISO 20' Container size? ..

Ans: We have given a minimum required height of 2.6m from the floor.

7. Please specify what you mean by connection kit and the quantity that you require. This relates to whether we need to prepare stairways.

Ans: No staircase required. The connecting kit here refers to the screws, nuts, etc required for the installation of the prefabs

8. Regarding the electrical installation, which country uses the VDE 100 standard? Are there any alternative standards?

Ans: Kindly use that or an equivalent.

9. For the wall width, is it possible for us to adjust the width if the total width complies with the ISO 20' size, and if the five panels fit on the long side and two panels on the short side?

Ans: Yes as long as each panel size is not less than 120cm